

Robert Busch



Analytical

Project:
Lead and Copper

17631 N. 25th Avenue ĩ Phoenix, AZ
Granite Oaks Water Users Association Project Number:
13-155
PO Box 1963 **Reported:** Prescott, AZ86302 10/06/26 15:43

Analyte

2655 Glenshandra (2614272-01) Drinking Water (Grab) Sampled: 09/28/26 08:00 Received: 09/30/26 09:25

Reporting

Analyte Result

Limit Units Dilution Batch Prepared Analyzed Method Notes

Legend Technical dba Legend Analytical

Total Metals

Copper <0.0050 0.0050 mg/L 1 B6J0188 10/05/26 14:00 10/05/26 21:54 EPA 200.8 D1 Lead <0.0050 0.0050 mg/L 1 B6J0188 10/05/26 14:00 10/05/26 21:54 EPA 200.8 D1

2560 Glenshandra (2614272-02) Drinking Water (Grab) Sampled: 09/28/26 08:00 Received: 09/30/26 09:25

Reporting

Analyte Result

Limit Units Dilution Batch Prepared Analyzed Method Notes

Legend Technical dba Legend Analytical

Total Metals

Copper <0.0050 0.0050 mg/L 1 B6J0188 10/05/26 14:00 10/05/26 22:14 EPA 200.8 D1 Lead <0.0050 0.0050 mg/L 1 B6J0188 10/05/26 14:00 10/05/26 22:14 EPA 200.8 D1

2535 Glenshandra (2614272-03) Drinking Water (Grab) Sampled: 09/28/26 08:15 Received: 09/30/26 09:25

Reporting

Analyte Result

Limit Units Dilution Batch Prepared Analyzed Method Notes

Legend Technical dba Legend Analytical

Total Metals

Copper <0.0050 0.0050 mg/L 1 B6J0188 10/05/26 14:00 10/05/26 22:18 EPA 200.8 D1 Lead <0.0050 0.0050 mg/L 1 B6J0188 10/05/26 14:00 10/05/26 22:18 EPA 200.8 D1

2054 Twin Oaks (2614272-04) Drinking Water (Grab) Sampled: 09/28/26 09:00 Received: 09/30/26 09:25

Reporting

Analyte Result

Limit Units Dilution Batch Prepared Analyzed Method Notes

Legend Technical dba Legend Analytical

Total Metals

Copper <0.0050 0.0050 mg/L 1 B6J0188 10/05/26 14:00 10/05/26 22:23 EPA 200.8 D1 Lead <0.0050 0.0050 mg/L 1 B6J0188 10/05/26 14:00 10/05/26 22:23 EPA 200.8 D1

2375 Twin Oaks (2614272-05) Drinking Water (Grab) Sampled: 09/28/26 09:00 Received: 09/30/26 09:25

Reporting

Analyte Result

Limit Units Dilution Batch Prepared Analyzed Method Notes

Legend Technical dba Legend Analytical

Total Metals

Copper <0.0050 0.0050 mg/L 1 B6J0188 10/05/26 14:00 10/05/26 22:28 EPA 200.8 D1 Lead <0.0050 0.0050 mg/L 1 B6J0188 10/05/26 14:00 10/05/26 22:28 EPA 200.8 D1

2570 Charter Oaks (2614272-06) Drinking Water (Grab) Sampled: 09/28/26 09:00 Received: 09/30/26 09:25

Reporting

Analyte Result

Limit Units Dilution Batch Prepared Analyzed Method Notes

Legend Technical dba Legend Analytical

Total Metals

Robert Busch Association
Granite Oaks Water Users Project:
PO Box 1963 Reported: Prescott, AZ86302 10/06/26 15:43

Project Number:
Lead and Copper 13-155

2570 Charter Oaks (26I4272-06) Drinking Water (Grab) Sampled: 09/28/26 09:00 Received: 09/30/26 09:25

Reporting

Analyte Result

Limit Units Dilution Batch Prepared Analyzed Method Notes

Legend Technical dba Legend Analytical

Total Metals

Copper <0.0050 0.0050 mg/L 1 B6J0189 10/05/26 14:30 10/05/26 22:57 EPA 200.8 D1 Lead <0.0050 0.0050 mg/L 1 B6J0189 10/05/26 14:30 10/05/26 22:57 EPA 200.8 D1

2568 Post Oak (26I4272-07) Drinking Water (Grab) Sampled: 09/28/26 09:30 Received: 09/30/26 09:25

Reporting

Analyte Result

Limit Units Dilution Batch Prepared Analyzed Method Notes

Legend Technical dba Legend Analytical

Total Metals

Copper <0.0050 0.0050 mg/L 1 B6J0189 10/05/26 14:30 10/05/26 23:21 EPA 200.8 D1 Lead <0.0050 0.0050 mg/L 1 B6J0189 10/05/26 14:30 10/05/26 23:21 EPA 200.8 D1

2585 Post Oak (26I4272-08) Drinking Water (Grab) Sampled: 09/28/26 09:30 Received: 09/30/26 09:25

Reporting

Analyte Result

Limit Units Dilution Batch Prepared Analyzed Method Notes

Legend Technical dba Legend Analytical

Total Metals

Copper <0.0050 0.0050 mg/L 1 B6J0189 10/05/26 14:30 10/05/26 23:26 EPA 200.8 D1 Lead <0.0050 0.0050 mg/L 1 B6J0189 10/05/26 14:30 10/05/26 23:26 EPA 200.8 D1

8660 Live Oak (26I4272-09) Drinking Water (Grab) Sampled: 09/28/26 09:45 Received: 09/30/26 09:25

Reporting

Analyte Result

Limit Units Dilution Batch Prepared Analyzed Method Notes

Legend Technical dba Legend Analytical

Total Metals

Copper <0.0050 0.0050 mg/L 1 B6J0189 10/05/26 14:30 10/05/26 23:31 EPA 200.8 D1 Lead <0.0050 0.0050 mg/L 1 B6J0189 10/05/26 14:30 10/05/26 23:31 EPA 200.8 D1

8800 Live Oak (26I4272-10) Drinking Water (Grab) Sampled: 09/28/26 09:45 Received: 09/30/26 09:25

Reporting

Analyte Result

Limit Units Dilution Batch Prepared Analyzed Method Notes

Legend Technical dba Legend Analytical

Total Metals

Copper <0.0050 0.0050 mg/L 1 B6J0189 10/05/26 14:30 10/05/26 23:41 EPA 200.8 D1 Lead <0.0050 0.0050 mg/L 1 B6J0189 10/05/26 14:30 10/05/26 23:41 EPA 200.8 D1

Sample Condition Upon Receipt:

Temperature: 20.60 °C

All samples were received in acceptable condition unless noted otherwise in the case narrative.

Case Narrative:

Holding Times: All holding times were met unless otherwise qualified.

QA/QC Criteria: All analyses met method requirements unless otherwise qualified.

Accreditations: AZ(PHX)0004, AZ(TUC)0004, CDC ELITE Member.

Accreditation is applicable only to the test methods specified on each scope of accreditation held by LEGEND. **Comments:**

There were no problems encountered during the processing of the samples, unless otherwise noted. All samples were analyzed on a "wet" basis unless designated as "dry weight".

Notes and Definitions

ND Non-Detect

D1 Sample required dilution due to matrix.