

SOMETHING YOU SHOULD KNOW ABOUT YOUR WATER SYSTEM

Granite Oaks Water Users Association takes water samples from two areas within the water system. We sample water from the wells every month and periodically test for specific contaminants. We test for dozens of contaminants as required by regulations and results of these tests are posted on our website in our annual Consumer Confidence Report.

In addition, we take samples annually from within the distribution system and test for lead and copper. Since we have no lead and copper lines within the system, it is unlikely that an actionable level of either of those contaminants will be introduced from within the service lines. Nevertheless, we are required to take 10 samples per year from within the distribution system and test for lead and copper. We failed to do that in 2025. As stated in the notice, the water is still safe to drink, and you need to take no action.

Lead and Copper Monitoring Requirements Not Met for Granite Oaks Water Users Association

On January 10th, we became aware that our system recently failed to collect the correct number of drinking water samples for the Lead and Copper Rule. Although this incident was not an emergency, as our customers, you have a right to know what happened and what we are doing to correct this situation.

We are required to monitor your drinking water for specific contaminants on a regular basis.

Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. During June 2025 through September 2025, we were required to sample 10 lead and copper samples within the system. We did not collect any.

What should I do?

There is nothing you need to do. You do not need to boil your water or take other corrective actions. You may continue to drink the water. If a situation arises where the water is no longer safe to drink, you will be notified within 24 hours.

What is being done?

Samples will be collected in June 2026 to return the system back to compliance.

Please contact Bob Busch at rmbusch1@gmail.com if you have any questions.

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

This notice is being sent to you by Granite Oaks Water Users Association.

State Water System ID #: AZ0413155 Date distributed: 2/19/26.